

GEM BID NO.-GEM/2023/B/3423912
START DATE: 08/05/23, TIME: 5.33PM
END DATE: 18/05/23, TIME: 6:00 PM

TECHNICAL SECIFICATION

Sl. No.	DESCRIPTION OF MATERIAL	QUANTITY
01.	Refilling of fire extinguishers (as per IS 2190) and Hydraulic Pressure testing (as per IS2878) and operational test . Validity: Refilling agent shall be valid for 5 years Specification: 6.8 kg CO2	77 Nos.
02.	Refilling of fire extinguishers (as per IS 2190) and Hydraulic Pressure testing (as per IS2878) and operational test . Validity: Refilling agent shall be valid for 5 years Specification: 2 kg CO2	62 Nos.